

Hite associates

ARCHITECTURE / PLANNING / TECHNOLOGY

ADDENDUM NO. 2

October 12, 2023

Project: **North Duplin Jr.-Sr. High School Classroom Addition**
Duplin County Schools

TO: ALL BIDDERS

The following items clarify, add to, delete from, and / or otherwise change and supersede information previously issued to you in the bidding documents for the referenced project. Please read them carefully and adjust your bid accordingly.

Please note that addendums, and all revised documents are available via Hite Associates website www.hiteassoc.com under the "Contractor Resources" link.

ADDENDUM NO. 2

1. **BID DATE & TIME CHANGE:** Bids will be moved to **Wednesday, October 25, 2023, at 2:30 PM**, at Duplin County Schools Facilities, 249 S NC HWY 11 & 903, Kenansville, NC 28349.
2. Section 09510 Acoustical Ceilings is added.
3. Drawing E101: Eliminate 400A meter base. Existing transformer is currently metered at the transformer enclosure. Feeder from transformer should terminate at the 400A, Nema-3R, SE Rated disconnect switch as indicated.

END OF ADDENDUM NO.2



James G. Hite, AIA, Project Architect
Hite Associates, PC

BIDDERS, PLEASE NOTE THAT REFERENCED REVISED DOCUMENTS AND DRAWING REVISIONS ARE MARKED AS SUCH ON THE REVISION BLOCK ON THE PLANS AND ARE TO BE ACCESSED ON THE HITE ASSOCIATES WEBSITE.

ALL BIDDERS, SUBCONTRACTORS, AND MATERIAL SUPPLIERS ARE TO USE THE HITE ASSOCIATES WEBSITE ONLY, FOR ACCURATE AND COMPLETE BID DOCUMENTS.

Revised / Added Documents:

Table of Contents
Section 09510 Acoustical Ceilings
Drawing E101

cc: All Attendees / All Bidders / Roger Jones / Jody Gurganus

dist.: JGH / RBE / WP

File: Bids & Addenda